



UPSTREAM FLANGES

HOUSING CONFIGURATION	HEIGHT "H"	WIDTH "D"
1 x 1	29 3/4"	27"
1 x 2	59 1/2"	51"
1 x 3	89 1/2"	75"
2 x 1	27"	27"
2 x 2	51"	51"
2 x 3	75"	75"
3 x 1	27"	27"
3 x 1	89 1/2"	51"
3 x 3	75"	75"
4 x 1	27"	27"
4 x 2	51"	51"
4 x 3	75"	75"

HEPA BAG-IN/BAG-OUT HOUSING FLUID SEAL SPECIFICATIONS

1. CONSTRUCTION: UNIT IS TO BE SEAL WELDED. BAG-IN/BAG-OUT DESIGN.
2. MATERIAL: HOUSING IS CONSTRUCTED FROM 12 GA AND 14 GA TYPE T-304L S/S. HARDWARE WILL BE 300 SERIES S/S.
3. UNIT COMES EQUIPPED WITH A REMOVABLE LOCKING MECHANISM FOR FLUID SEAL FINAL FILTERS.
4. ACCESS DOORS SHALL BE SUPPLIED WITH BAG KITS
5. THE STANDARD BAG-IN/BAG-OUT COMES WITH AN ACCESS DOOR ON ONE SIDE. STANDARD HOUSING IS A RIGHT HAND ACCESS. THE BUYER MUST SPECIFY LEFT HAND IF REQ'D.
6. HOUSING MORE THAN 3 WIDE CONSISTS OF TWO SIDE-BY-SIDE HOUSINGS IN PARALLEL. FILTER REMOVAL IS FROM BOTH SIDES OF HOUSING.
7. PREFILTER SIZE: 24"X24"X2", 4" DR 6" NDM. HEPA FILTER DIMENSION: 24" X 24" X 11 1/2" FOR OTHER SIZES PLEASE CONTACT FACTORY
8. PREFILTER CHANGE OUT BAG SIZE: 60C X 72 HEPA CHANGE OUT BAG SIZE: 104C X 96

FRONT VIEW

HOUSING CONFIGURATION _____ X _____
 HOUSING DIMENSION: _____ (H) _____ (W)
 HOUSINGS REQUIRED: _____

 TRI-DIM FILTER CORPORATION CORPORATE HEADQUARTERS: 93 INDUSTRIAL DRIVE LOUISA, VA. 23093		DRAWN BY:	APPROVED BY:	DATE:	SCALE:
		B. DUFFY	B. DUFFY	04-14-03	-
TITLE: TRI-LOCK BF BAG-IN/BAG-OUT FLUID SEAL HEPA HOUSING, WITH PREFILTER		DRAWING NUMBER: TLBF-0002			
IETI INDOOR ENVIRONMENTAL TECHNOLOGY, INC.		IDTT INTERNATIONAL TECHNOLOGY		REV.: A	